

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20254104
Address: 2111 SW HARVEST MOON LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed	Thursday, October 30, 2025

Corrective Action Required:

1	Misc	10/27/25 Tyler S. Erosion control was not installed before starting work digging the basement. Erosion control must be installed before work is to be done. Failed. 10/30/25 Tyler S. Be sure the entrance to all construction sites have rock down to keep mud from tracking out into the road. Also there is mud in the curb that needs cleaned up.
---	------	--

Comments: