

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250233
Address: 2611 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed	Thursday, October 30, 2025

Corrective Action Required:

1	Misc	10/30/25 Tyler S. there is quite a bit of mud and some gravel in the curb at the entrance of site. this needs cleaned up before it flows into our storm water system.
---	------	---

Comments: