

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20253369  
Address: 1130 SE RANCLAND ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Thursday, October 30, 2025

Corrective Action Required:

1	Misc	-fire block all wall space to ceiling space at kitchen/garage wall. Multiple areas into furr downs and outs -provide insulation behind tub/shower in bath 4 -seal penetration into landing great room/stairwell wall -seal penetrations from hvac chase to ceiling space
---	------	---

**Comments:**