

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253128
Address: 2606 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Drew Fischer	Failed	Thursday, October 30, 2025

Informational:

1 Misc

Portal frame front and rear nailing pattern good, ok to cover

Corrective Action Required:

2 Misc

2606 SW Farmfield

- portal frame bolt in garage must be in center 1/3rd of bottom plate
- Wires must be protected within 6' of attic opening
- Install plumbing vent roof boots
-

Comments: