

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20254088

Address: 212 NW ORCHARD CT, LEES SUMMIT, MO 64063 210 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|-------------------------------------|------------|----------|----------------------------|
| Sewer Service Inspection - R | Robb Popp | Failed | Thursday, October 30, 2025 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | Sleeve pipe through footing. Okay to backfill trenches |
|---|------|--|

Comments: