

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20254004
Address: 1232 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Shawn Hoffman	Partial	Thursday, October 30, 2025

Corrective Action Required:

1	Miscellaneous Correction	PARTIAL	- Partial from foundation 30' out, not connected to stub.
---	-----------------------------	---------	-----------------------------------------------------------

Comments: