

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250065  
Address: 620 SE WOOD LN, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed	Monday, November 03, 2025

Corrective Action Required:

1	Misc	Truss plans do not match trusses on site -fireblock garage walls into furr down -bonding screw missing at metallic boxes -bed 1 missing outlet -studs over bored for previous dryer vent routing dryer vent
---	------	---

**Comments:**