

CITY OF LEE'S SUMMIT

CODES ADMINISTRATION DEPARTMENT

220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200
Fax (816) 969-1201

PLAN REVIEW CONDITIONS

April 10, 2012

MCCOWN GORDON CONSTRUCTION
422 ADMIRAL BLVD SUITE 100
KANSAS CITY, MO 64106--1560

Permit No: PRCOM20120184
Project Title: SAINT LUKES EAST SURGICENTER
Project Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
Parcel Number: 52400043900000000
Location: SAINT LUKE'S HOSPITAL OF LEE'S SUMMIT LOT 1---LOT 1 (EX PT IN RD)
Type of Work: NEW TENANT FINISH
Occupancy Group: BUSINESS
Description: EXPANSION OF EXISTING TENANT SPACE

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Building Plan Review

Reviewed By: Michael Weisenborn

Approved

1. This project requires a third party review of the electrical systems.

Action required - Please provide documentation of approval of this review.

Mike Weisenborn 03/21/2012 11:07 AM - Provide the revised electrical sheets.

2. 2006 IBC 1008.1.2 - Door swing. Egress doors shall be side-hinged swinging.

Exceptions:

1. Private garages, office areas, factory and storage areas with an occupant load of 10 or less.
2. Group I-3 occupancies used as a place of detention.
3. Critical or intensive care patient rooms within suites of health care facilities.
4. Doors within or serving a single dwelling unit in Groups R-2 and R-3.
5. In other than Group H occupancies, revolving doors complying with Section 1008.1.3.1.
6. In other than Group H occupancies, horizontal sliding doors complying with Section 1008.1.3.3 are permitted in a means of egress.
7. Power-operated doors in accordance with Section 1008.1.3.2.
8. Doors serving a bathroom within an individual sleeping unit in Group R-1.

Doors shall swing in the direction of egress travel where serving an occupant load of 50 or more persons or a Group H occupancy. The opening force of interior side-swinging doors without closers shall not exceed a 5-pound force. For other side-swinging, sliding and folding doors, the door latch shall release when subjected to a 15-pound force. The door shall be set in motion when subjected to a 30-pound force. The door shall swing to a full-open position when subjected to a 15-pound force. Forces shall be applied to the latch side.

Action required - The door at the East end of Public Corridor 101 to the stair enclosure does not meet this requirement. Make needed corrections.

Mike Weisenborn 03/21/2012 11:07 AM - Provide the revised electrical sheets.

Fire Plan Review

Reviewed By: Jim Eden

Approved

- ☒ Approved to issue per the listed conditions.
☐ Do not issue per the listed conditions.
☐ Approved to construct foundation only per the listed conditions.
☐ Requires Final Development Plan approval prior to issuing this building permit.

The applicant agrees to incorporate the aforementioned requirements into the project to conform to applicable City Codes and Ordinances.

Signature of Applicant

Date

4/10/12

Print Applicant Name

Company Name

McCown Gordon

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.