

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245783
Address: 2 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Robb Popp	Partial	Monday, November 03, 2025

Informational:

1 Misc

- Ufer located at NW corner of electrical room
- (4) 3" conduit from transformer to building
- 4" conduit from south of building to east side for data

****Light poles**

- (3) light poles at SE lot
- (5) at west side
- From light pole at SE to ESO in island and to gas pump and to building

Comments: