

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250690
Address: 2237 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Not Ready	Friday, November 07, 2025

Corrective Action Required:

1	Misc	11/7/25	**Not ready for occupancy. Inspection incomplete. Fee assessed
---	------	---------	--

- Remove gutter buddy and debris from storm inlet
- Install deadbolt
- Garage door must self close and latch
- Complete all open electrical
- Missing cover plates throughout

Comments: