CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253342

Address: 893 SW LEMANS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Friday, November 07,

Commercial 2025

Corrective Action Required:

1 Misc -Fire approval required

-Secure all MC cables within 12" of panel and secure&support MC min every 6

ft

-Close open electrical box above cooler

-Label panel breakers

-Make sure cooler unit breakers size are per labels -Complete electrical above existing restroom

-Provide access to RTU

**Note: existing non-compliant restroom

Comments: