

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250352
Address: 1937 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Friday, November 07, 2025

Corrective Action Required:

1 Misc

- splash blocks and sump pump discharge shall extend 36" from foundation
- address pending sidewalk inspection
- provide lock out device for all hardwired electrical circuits
- provide (2) 1/2" through bolts at each deck post to beam connections

Comments: