

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253342
Address: 893 SW LEMANS LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Ready for Temp CO	Friday, November 07, 2025

Corrective Action Required:

1	Misc	-Secure all MC cables within 12" of panel and secure&support MC min every 6 ft -Close open electrical box above cooler -Label panel breakers -Make sure cooler unit breakers size are per labels -Complete electrical above existing restroom -Provide access to RTU
---	------	---

****Note:** existing non-compliant restroom

Comments: