

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRCOM20253342
Address: 893 SW LEMANS LN, LEES SUMMIT, MO 64082
Inspected On: Monday, November 10, 2025
Inspected By:
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Ready for Temp CO	Friday, November 07, 2025

Corrective Action Required:

1	Misc	-Secure all MC cables within 12" of panel and secure&support MC min every 6 ft -Close open electrical box above cooler -Label panel breakers -Make sure cooler unit breakers size are per labels -Complete electrical above existing restroom -Provide access to RTU
---	------	---

****Note:** existing non-compliant restroom

Comments: