

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20246426  
Address: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:       | Outcome: | Date:                     |
|---------------------------------|------------------|----------|---------------------------|
| <b>Above Ceiling Inspection</b> | Mitchell Schwarz | Failed   | Monday, November 10, 2025 |

Corrective Action Required:

|   |      |                                                                                            |
|---|------|--------------------------------------------------------------------------------------------|
| 1 | Misc | -Missing hangers and LVL's at landing<br>-add blocking where missing above N most bathroom |
|---|------|--------------------------------------------------------------------------------------------|

**Comments:**