

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20251165

Address: 628 SE BRADFREE ST, LEES SUMMIT, MO 64063630 SE BRADFREE ST, LEES SUMMIT, MO 64063632  
SE BRADFREE ST, LEES SUMMIT, MO 64063626 SE BRADFREE ST, LEES SUMMIT, MO  
64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection</b>	Mitchell Schwarz	Failed	Monday, November 10, 2025

Corrective Action Required:

1	PW-Devices for Erosion and Sediment Control	5-5-25 Dustin A, Erosion control had been installed and construction entrances are being installed.
---	---	---

Corrective Action Required:

2	Misc	-Silt fence downed throughout lot -dirt on top of storm box -
---	------	---

**Comments:**