

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20253261
Address: 2622 SW FARM FIELD RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, November 10, 2025

Informational:

1 Misc

Portal frame nailing pattern is ok at garage and back porch. Ok to cover

Corrective Action Required:

3 Misc

- Tie rafter to joists together in bed 2 and bathroom on main floor

- Anchor bolts to be in the middle third of sill plate throughout basement

- Provide approved material on vertical fire blocking

Comments: