

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20253531
Address: 1451 SE BAILEY FARMS PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Service Inspection	Dustin Agcopra	Passed	Monday, November 10, 2025

Informational:

1	Misc	11-7-25 Dustin A, Contractor called for a water service inspection. The 2 inch copper is kinked at the tap . I called water and they do not want any kinks in the copper, I talked the contractor and let him know and he was going to try to figure something out .
		11-10-25 Dustin A, Contractor was able to fix the kink. Water has now passed

Comments: