

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246324

Address: 2094 NW OBRIEN RD, LEES SUMMIT, MO 640812098 NW OBRIEN RD, LEES SUMMIT, MO 640812090
NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Inspection - Residential	Robb Popp	Failed	Wednesday, November 12, 2025

Corrective Action Required:

1	Misc	-No City inspections were performed on the construction of retaining wall. Provide engineered report for acceptance of and completion of footings and wall design as per engineered plans
---	------	--

Comments: