

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20245783  
Address: 2 NE TUDOR RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Robb Popp	Partial	Wednesday, November 12, 2025

Informational:

1 Misc

- Ufer located at NW corner of electrical room
- (4) 3" conduit from transformer to building
- 4" conduit from south of building to east side for data

**\*\*Light poles**

- (3) light poles at SE lot
- (5) at west side
- From light pole at SE to ESO in island and to gas pump and to building
- Ground loop at south and east side

**Comments:**