

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20251166

Address: 655 SE BRADFREE ST, LEES SUMMIT, MO 64063657 SE BRADFREE ST, LEES SUMMIT, MO 64063659  
SE BRADFREE ST, LEES SUMMIT, MO 64063653 SE BRADFREE ST, LEES SUMMIT, MO  
64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Mitchell Schwarz	Failed	Wednesday, November 12, 2025

Corrective Action Required:

1	Misc	DO NOT INSULATE
---	------	-----------------

Throughout  
-will check GB bracing at time of drywall  
-provide H2.5 per plans

Check plans and all trusses throughout

653

655

657

-address broken truss above bedroom 1  
(Fix to engineer specifications)

659

**Comments:**

