



Date: 11/11/2025
To: Sean Owens, Collins | Webb ARCHITECTURE
From: John Funk
Address: Reunion at Blackwell
SE Shenandoah Dr.
Lee's Summit, MO 64063

Mr. Owens,

This letter serves to provide a narrative for the items that were revised on Building A at the contractor's request. The list of revisions are as follows broken down per sheet:

Sheet S101 A

1. Updated garage door header to LVL.
2. Updated stud pack bearing studs under the girder truss.

Sheet S101 A-1

1. Updated truss layout to match truss shop drawings and field layouts.

STAND Structural Engineering, Inc.

8234 Robinson St., Overland Park, KS 66204 913-214-2169 stand-sei.com