

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246426
Address: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Mitchell Schwarz	Partial	Wednesday, November 12, 2025

Corrective Action Required:
2 Misc

- fire block wall space to under stair area at stair line
- address broken stud at "shipping and receiving"
- jack stud at "shipping and receiving" door to short
- bond all metallic boxes in warehouse area
- Missing hanger at landing

Okay to insulate

Comments: