

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250690
Address: 2237 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|---------------------------|
| Occupancy Inspection - Codes Residential | Robb Popp | Failed | Friday, November 14, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | -Remove gutter buddy and debris from storm inlet -Locate sewer tracer wire box at grade -Provide 6" clearance to siding at west side -Install security screws at basement door -Install missing hangers at deck joists -Label non GFCI receptacle at sump pump |
|---|------|---|

Comments: