CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252043

Address: 1221 SE CRONIN ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Not Ready Friday, November 14,

Residential 2025

Corrective Action Required:

1 Misc

-sod

-splash blocks and sump pump discharge to extend 36" from foundation

-address failed sidewalk inspection

-provide landing at deck stairs

-deck Beam span greater than allowed by code max span for (2) 2x12 beam

with 10' 2x10 joist 16" OC is 8'7"

-garage entry door must be self closing and Latching

-missing hand rails to basement-missing sheet rock under stairs

Comments: