Facility : Lee's Summit Medical Center
Project: Medsurg & Dietary Expansion - Temp Kitchen

DGL Project No: 6406.24.0001
Date: 10/21/2025

ADDENDUM "1"- ASI-001 - DESIGN COORDINATION

#	Sheet #	Revision Narrative
ARCHITECTURAL		
1	GI000	Added submittal titles and date for Design Coordination.
2	GI001	Updated sheet index.
CIVIL		
1	C5.3	Updated grease interceptor location.
PLUMBING		
1	P02-01	Removed 1,000 gallon above ground waste storage tank. Added new 1,250 gallon grease interceptor and associated grease waste piping for new location.
MEPT		
1	MEPT01-00	Removed 1,000 gallon above ground waste storage tank. Added new 1,250 gallon grease interceptor at new location.
ELECTRICAL		
1	E02-01	Removed power for grease tank heaters.
2	E06-00	Removed power for grease tank heaters.