



Facility : Lee's Summit Medical Center

Project: ED Expansion

DGL Project No: 6406.24.0003

Date: 10/24/2025

### ADDENDUM "2" - ASI-002 - DESIGN COORDINATION

#	Sheet #	Revision Narrative
<b>ARCHITECTURAL</b>		
1	GI000	Added submittal titles and date for ASI-002 Design Coordination.
2	GI001	Updated sheet index.
3	AE101	Revised per added Bailey Hill in lieu of Prox Cabs in exam rooms.
4	AE181	Added reception security glazing.
5	AE401	Revised per added Bailey Hill in lieu of Prox Cab in Trauma Room. Revised Single to dual time clock.
6	AE402	Revised per added Bailey Hill in lieu of Prox Cabs in exam rooms.
7	AE403	Revised per added Bailey Hill in lieu of Prox Cabs in A.I.I. Exam.
8	AE407	Added reception security glazing.
9	AE601	Revised door hardware per state health comments.
10	AE720	Added security glazing details.
<b>INTERIORS</b>		
1	AF001	MATERIAL CONTACTS - CORIAN, DAL TILE, EMSER TILE: Updated rep information
2	AF001	CASEWORK - PL3, Added new laminate for Waiting/Reception per owner request
3	AF001	WALL PROT. CONFIGURATIONS - WP8, Added sheet protection under chair rail
4	AF002	I: CASEWORK DESIGNS - 1. Updated plastic laminate to PL3.
5	AF101	RECEPTION 1-1404 - Updated plastic laminate to PL3
6	AF102	WAITING 1-1403, Added sheet protection under chair rail
<b>ELECTRICAL</b>		
1	E05-01	Revised power for Prox cabs to wall mounted Bailey Hill arm.
2	E05-01	Revised Trauma room time clock from single to dual mount.
<b>TECHNOLOGY</b>		
1	T02-01	Revised data for prox cabinets from 69" AFF to 18" AFF for Bailey Hill arm.