

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20250016
Address: 628 SE HIGHLAND PARK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, November 18, 2025

Corrective Action Required:

1 Misc

Portal frame inspection only

- Front door and garage door. PFH portal frames OK
- hold downs in second floor mechanical closet OK
- Missing hold downs at trusses at front porch
- nail pattern on structural osb at front of house. OK

OK to cover front of house and drywall mechanical closet on second floor.

Comments: