

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20241886  
Address: 251 NE ALURA WAY, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	Khanh Nguyen	Failed	Tuesday, November 18, 2025

Corrective Action Required:

1	FOURTH FLOOR	Framing of roof assembly: -Install draft-stop above demising wall at every two units, or 3000 square ft, whichever is less -Install double 2x solidblock under parapet walls; solidblock under corner posts to (3x)2x10 -Install 2 H8 straps at each side of lvl beam per plan, or have engineer address
---	--------------	---

**Comments:**