

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20251576  
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	Khanh Nguyen	Failed	Wednesday, November 19, 2025

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 1 | Misc | -Have engineer to address undermined footing by trenches dug adjacent to footing |
|   |      | -Provide venting for traps connected to waste stacks that are offset             |

**Comments:**