CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252932

Address: 1206 SE WINDBREAK DR, LEES SUMMIT, MO 640811204 SE WINDBREAK DR, LEES SUMMIT, MO

64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection -

Residential

Mitchell Schwarz F

Failed

Thursday, November

20, 2025

Corrective Action Required:

1 Misc

Both side

-address separation wall sill plate in garage bearing and anchor bolts blowing

out stem wall

-insulate behind tub shower enclosures at exterior

1204

-separation of all to extend to sheathing attic space above garage

-address open electrical at NE primary bedroom corner

-seal top plate penetration at primary bedroom entry and bottom plate at

windows

1206

-top plate penetration at laundry/primary closet

Comments: