

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20251576
Address: 2200 NE DOUGLAS ST, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|--------------------------------|
| Underslab Plumbing Inspection - Commercial | Khanh Nguyen | Partial | Thursday, November 20, 2025 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -Fire riser OK -Sanitary drain OK, except for the incomplete floor sink drain from sprinkler room -Have engineer to address undermined footing by trenches dug adjacent to footing |
|---|------|--|

Comments: