

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20233629  
Address: 3215 SW ENOCH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                     | Inspector:   | Outcome: | Date:                       |
|---|--------------|----------|-----------------------------|
| <b>Occupancy Inspection - Codes Residential</b> | Drew Fischer | Failed   | Thursday, November 20, 2025 |

Corrective Action Required:

|   |      |   |
|---|------|---|
| 1 | Misc | - Provide (2) 1/2" through bolts at each post to beam connections at deck |
|   |      | -   |
|   |      | - Label non GFCI receptacle at sump                                       |
|   |      | -   |
|   |      | - Obtain a Sprinkler permit   |
|   |      | -   |

Corrective Action Required:

|   |      |  |
|---|------|--|
| 2 | Misc | 3215 SW Enoch  |
|   |      | - Seal exterior penetration at AC lines                            |
|   |      | - Label refrigerator outlet in garage as non gfci                  |
|   |      | - Security screws needed in hinges of rear patio door              |
|   |      | - Continuous handrail needed on deck stairs as per code R311.7.8.4 |
|   |      | - obtain irrigation permit   |

**Comments:**