CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 FAX (816) 969-1201 (816) 969-1200

Temporary Certificate of Occupancy

Permit #: PRRES20240585

Address: 3232 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

Inspected On: Thursday, November 20, 2025

Inspected By: Development Center

Expiration Date: 12/20/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Thursday, August 15, 2024

Residential

Corrective Action Required:

Pay all fees Misc

> -address pending driveway inspection -address pending pier inspection -provide as graded plot plan

-final grade and sod

-will check water meter at time of final grade

-splash blocks and sump pump discharge to extend 36" from foundation

-seal all exter penetrations and top of a/c disconnect

Comments: