

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20232901

Address: 506 SE LINDBERG LN, LEES SUMMIT, MO 640632914 SE 5TH TER, LEES SUMMIT, MO 64063505 SE  
LINDBERG LN, LEES SUMMIT, MO 64063603 SE LINDBERG LN, LEES SUMMIT, MO  
640632960 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection</b>	Dustin Agcopra	Failed	Friday, November 21, 2025

### Corrective Action Required:

1 Misc 10-29-25 Dustin A, Erosion control Failed, oil leaking from asphalt equipment is on the road aprox 250 ft, Loader was tracked up the street and there is mud . Needs to be cleaned .. Two- Day Notice

11-21-25 Dustin A, Multiple lots have silt fence down are lacking all together, Needs to be rectified by

11-25-25 or a STOP WORK order will be issued .

### Comments: