

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20244682  
Address: 19 NE SYCAMORE ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection</b>	John Jackson	Partial	Friday, November 21, 2025

Informational:

1 Misc

06/13/25 Friday JMJ (Level)

Talked to contractor about cleaning up Main St. & Sycamore from soil being track-out into the street.

07/03/25 Thursday JMJ (Level)

Talked with contractor about keeping the street clean Bash Excavating is removing soil.

07/17/25 Friday JMJ (Level)

Contractor needs to repair silt fencing, clean adjacent streets, and trim vegetation around project.

08/12/25 Tuesday JMJ (Level)

Erosion control inspection appears to be functioning.

09/03/25 Wednesday JMJ (Level)

Contractor needs to reestablish silt fencing Northside of project.

09/24/25 Wednesday JMJ(Level-Shane)

Contractor needs to reestablish silt fencing and clean adjacent street of silt erosion on street.

10/29/25 Wednesday JMJ(Level-Shane)  
Contractor maintaining erosion control devices.

11/21/25 Friday JMJ (Level-Shane)  
Contractor continue to maintain erosion control devices on site.

**Comments:**