

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20250106  
Address: 1817 NE LASHBROOK CIR, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Nick Scott	Passed	Monday, November 24, 2025

Informational:

1 Misc

5-13-25 NS Site visited and it appears that driveway and sidewalk have not been put in and will not be ready for a while.  
10/16/25 Tyler S. DW needs to be compacted. Dirt in rock and rock is shallow in areas. Must be a minimum of 4" of aggregate and clean rock. Fail.  
11-24-25 Site visited and it appears that driveway meets city standards. Look at plot plan a sidewalk is to connect to only one side of driveway. Passed

**Comments:**