

LEE'S SUMMIT FIRE DEPARTMENT

FIRE HEADQUARTERS
207 SE DOUGLAS STREET
LEE'S SUMMIT, MISSOURI 64063-2372
(816) 969-1300
FAX (816) 969-1313
TDD (816) 969-7407

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20110083	Date:	April 17, 2012
Project Title:	CVS Pharmacy	Applicant:	
Location:	621 SW 3RD ST. LEES SUMMIT, MO 64063	Vector Security	
Type of Work:		2500 Maitland Ctr. Pkwy, Suite 105	
Occupancy Group:	M	Maitland, FL 32751	
Description:	CVS Pharmacy Building	(407)475-1110	
Construction Type:	Type VB (Unprotected)		
Map Page:	195F		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Jim Eden

Rejected

1. 2006 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

2. Provide interior notification appliances throughout the building. Resubmit plans.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.