

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252889
Address: 2627 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Tyler Schreck	Failed	Monday, November 24, 2025

Corrective Action Required:

1	Misc	10/24/25 Tyler S. Dirt and rocks pile at curb right of the driveway is spilling out over straw waddle and into the street. With all the rain thats coming the pile needs to be moved back and sufficient erosion control must be in place. If this doesnt get corrected quickly, will result in a 2 day stop work order. Also there is not erosion control to the left of the driveway. 11/24/25 Tyler S. No erosion control up on the right side of driveway. Needs corrected ASAP. Fail.
---	------	---

Comments: