

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20252931

Address: 1218 SE WINDBREAK DR, LEES SUMMIT, MO 64081  
1216 SE WINDBREAK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                          | Inspector:       | Outcome: | Date:                      |
|--------------------------------------|------------------|----------|----------------------------|
| <b>Electrical Service Inspection</b> | Mitchell Schwarz | Failed   | Tuesday, November 25, 2025 |

### Corrective Action Required:

|   |      |                                                                                            |
|---|------|--------------------------------------------------------------------------------------------|
| 1 | Misc | clams not installed correctly at gas line.<br>Ufer connection used is not listed for rebar |
|---|------|--------------------------------------------------------------------------------------------|

### Comments: