

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20192646
Address: 3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Tuesday, November 25, 2025

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">-Complete corrections for all other departments-Building is occupied and stocked without authorization and inspection-Install cover at exterior receptacles-Toilets in both restrooms required to be 16" to 18" to centerline from the sidewall-The guardrail at east and west stairs is below 42"-Install weather proof boxes and covers at all exterior columns-Provide permanent signage at electrical rooms-Open electrical at northwest columns-No site lighting, parking or accessible parking is complete-Piers and underground electrical to site have been installed without inspection-Label RTUs |
|---|------|---|

Comments: