

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20246426
Address: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Partial	Wednesday, November 26, 2025

Corrective Action Required:

1	Misc	11-14-25 Dustin A, SW was called for a proof roll, after walking it there are several spots where the gravel is not 4 inches or its bare dirt. Aggregate needs to be min of 4 in compacted . fail 11-17-25 Dustin A, Sw errors were corrected
---	------	--

Comments: