



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20114943, Building Permit - Commercial
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	John Borns	Partial	Wednesday, April 18, 2012

Partial Correction
1 MISC

OK TO COVER WHEN READY LIGHTNING PROTECTION RING
CONDUCTOR TRENCHED OUTSIDE BUILDING WALL FROM SW
CORNER TO SE CORNER TO NE CORNER; THEN FROM DD/0.2
TO B/0.2;

Comments: