

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200

**OnlinePortal at DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20253562  
Address: 1134 SE RANCLAND ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Monday, December 01, 2025

**Corrective Action Required:**

1	Misc	All exterior sheathing and 1/2" osb used for fire blocking can not be used and is not to code (see R302.11.1 for approved fireblocking materials) see 2nd floor hvac chase
---	------	--

Address notched truss D1 above front porch

**Comments:**