

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20250182
Address: 1001 SW JEFFERSON XING, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mitchell Schwarz	Failed	Tuesday, December 02, 2025

Corrective Action Required:
1 Misc

Submit prefabricated building, building plans.

walk in freezer/cooler area
-anchor bolts not spaced correctly plans call for 24" OC
-fasten exterior walls together to plans
-fire stop at ceiling line

Comments: