

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241004
Address: 2532 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, December 03, 2025

Corrective Action Required:

1	Misc	-Final grade, sod, downspout and sump pump extension **provide min 36" of storm water discharge from foundation wall at downspouts -Provide sewer tracer wire port at grade -Install two 1/2" lag screws (or approved screws) at each end of deck ledger board **near the stair landing, install 2 screws at end of ledger board
---	------	--

Comments: