

Temporary Certificate of Occupancy

Permit #: PRRES20241005
Address: 1628 SW ARBORWAY TER, LEES SUMMIT, MO 64082
Inspected On: Wednesday, December 03, 2025
Inspected By: Development Center
Expiration Date: 1/2/2026 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Wednesday, September 11, 2024

Corrective Action Required:

1	Misc	-address pending driveway inspection -address pending sidewalk inspection -address pending pier inspection -pay all fees -provide as graded plot plan -final grade and sod -will check water meter at time of final grade and sod -sump pump and splash blocks to extend 36" from foundation -obtain issued lawn irrigation permit
---	------	--

Comments: