CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20243784

Address: 1539 SW ARBOR VALLEY DR, LEES SUMMIT, MO 64082

Inspected On: Wednesday, December 03, 2025

Inspected By: Development Center
Expiration Date: 5/31/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Drew Fischer Ready for Temp CO Thursday, May 01, 2025

Residential

Corrective Action Required:

1 Misc -pay all fees

-final grade

-provide as graded plot plan

-sod

-splash blocks and sump pump discharge to extend 36" from foundation

2025

-will check water meter at time of final grade and sod

-obtain issued lawn irrigation permit

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Monday, March 31,

Residential

Corrective Action Required:

L Misc -pay all fees

-final grade

-provide as graded plot plan

-sod

-splash blocks and sump pump discharge to extend 36" from foundation

-will check water meter at time of final grade and sod

-obtain issued lawn irrigation permit

Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, February 27, 2025
Corrective Action Required:			
1 Misc	•	pump discharge to extend 3 at time of final grade and so	

Comments: