

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20252360
Address: 1312 SE WINDBREAK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Thursday, December 04, 2025

Corrective Action Required:

2	Misc	Pay all fees -properly secure/ supported handrail at top of stairs to basement. -multiple circuits not Afci protected (210.12) -label non gfci outlet in basement
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: