CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200

OnlinePortal at DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20252403
Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mitchell Schwarz	Failed	Friday, December 05, 2025

Corrective Action Required:

1	Misc	Address all outstanding items from other departments -provide exit signage at S side of building -provide AASSE1022 backflow device at soda machine -handrails to be 34”-38” ensure all ends terminate back to post Okay to stock and train

Comments: